PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

ISOMÉTRICO DO SISTEMA DE HIDRANTES



LEGENDA ISOMÉTRICO

	RESERVA DE INCÊNDIO DISPONÍVEL DE 12,00 m³
	TUBULAÇÃO DE ÁGUA PARA INCÊNDIO - AÉREA (AÇO GALVANIZADO)
	TUBULAÇÃO DE ÁGUA PARA INCÊNDIO - ENTERRADA
	BOMBAS DE RECALQUE PARA INCÊNDIO BOMBA PRINCIPAL { - PRESSÃO = 65,00 mca - VAZÃO = 530,00 lpm BOMBA JOCKEY { - PRESSÃO = 65,00 mca - VAZÃO = 530,00 lpm
	HIDRANTE SIMPLES
	ACIONADOR MANUAL DA BOMBA DE INCÊNDIO
	VÁLVULA DE BLOQUEIO
	VÁLVULA DE RETENÇÃO
	REGISTRO DE RECALQUE
	PRESSOSTATO
	JUNTA DE UNIÃO
	MANÔMETRO

João Manoel dos Santos
Presidente da Câmara Municipal de Piracicaba
Responsável pelo uso

Engº Civil Reinaldo Frasseto da Silva
Responsável Técnico

PROJETO TÉCNICO DE SEGURANÇA CONTRA INCÊNDIO
ISOMÉTRICO DO SISTEMA DE HIDRANTES

02/05

TOPSEG
PROJETOS E PERÍCIAS LTDA
topseg_engenharia@yahoo.com.br

Ocupação:	Câmara Municipal de Piracicaba - (Repartição Pública) D-1		
Local:	Rua Alferes José Caetano - nº 834 - Centro - Piracicaba-SP		
Proprietário:	Câmara Municipal de Piracicaba		
Resp. pelo Uso:	João Manoel dos Santos - Presidente da Câmara Municipal de Piracicaba		
Resp. Técnico:	Reinaldo Frasseto da Silva	CREA: 5063460957	ESCALA: S/ ESC
Áreas Existente:	3.158,55 m²	Total: 3.158,55 m²	

Folha A1

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT
PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT
PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT
PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT